



Purchasing
136 Services Building
Marquette, MI 49855-5317
906 227-2360
Email: purchase@nmu.edu

ADDENDUM #1

Bid No: 7767

Project: Hunt and Van Antwerp Hall Fire Alarm
System Replacement Project

Today's Date: 11/10/23

Due Date: 11/30/2023 (revised below)

Revised bid due date: **Thursday, November 30, 2023 at 2:00 pm EDT.**

NMU will contract directly with Johnson Controls to do the final coordination/integration of the new duct smoke detectors with the existing energy recovery units (ERUs) in both Hunt and Van Antwerp Halls.

NMU will contract directly with Simplex for existing system deactivation and head end panel removal.

State Electrical and Office of Fire Safety permits are required.

Existing items to be turned over to Owner:

- Simplex 4100 main panel in basement mechanical room 16 of Quad II.
- Simplex monitoring panel face and internals at the Hunt/Van Antwerp desk in Quad II.
- 100 smoke detector heads.
- Simplex **4009 T** booster panels, (assume there is one per building). The other 4009 booster panels can be disposed of.

Specification Items:

Fire Alarm and Mass Notification Section 28 3100:

- a Paragraph 2.7 Magnetic Door Holders: Door hold open devices shall have either an extension arm or chain depending on its location. Contractor will need to field verify to determine which application is necessary.
- b. Paragraph 3.1 Equipment Installation: Factory backboxes are required for all devices including sounder bases.

Electrical Drawing Items:

ED-1 Refer to Sheet E2.2 (re-issued)

1. Deleted notification device in Storage 232 as indicated.

ED-2 Refer to Sheet E2.3 (re-issued)

1. Deleted notification devices in Storage 332 as indicated.

Drawings Issued: E2.2, E2.3

ALL OTHER BID REQUIREMENTS REMAIN THE SAME.

END OF ADDENDUM
